

WORKS CERTIFICATE 2.1

to EN 10204:2004
No. Z0850113_0002

Product:

HEKATHERM-LT

PE vent pipe in twin wall design with structured-wall outside and smooth inside

All PE grades used to produce the above product are virgin material complying with the requirements of the food and commodity law.

A product has an antistatic finish when its surface resistance is $\leq 10^{12} \Omega$. This value is achieved with the inner pipe of this product. That means the product has an antistatic finish/effect.

HEGLER PLASTIK GMBH
Oerlenbach, 2016-02-23



i.V. Dipl.-Ing. (FH) Sebastian Mauder
Manager Quality Department

This works certificate supersedes all former confirmations on the same subject matter. Details given in this document are to inform on our products and possible applications. They are not meant to give legal assurance of certain properties of the products or their suitability for a concrete field of application. Nor do they mean an exoneration from the responsibility of material inspection upon receipt or own tests. All supplies are subject to the General Terms of Sales and Delivery of HEGLER PLASTIK GmbH.